

Distributie Oltenia SA
Directia Exploatare&Mentenanata
Dpt. Exploatare 110 kV
CE 110 kV Alexandria

Date extrase din analizoarele de energie electrica pe parcursul anului 2016

Statia	Tabel 5					
	Tensiunea reziduala u %	Durata t [ms]				
		$10 \leq t \leq 200$	$200 < t \leq 500$	$500 < t \leq 1000$	$1000 < t \leq 5000$	$5000 < t \leq 60000$
Blejesti	$90 > u \geq 80$	16	2	1	4	1
	$80 > u \geq 70$	5	1	0	2	0
	$70 > u \geq 40$	1	7	3	3	0
	$40 > u \geq 5$	0	16	9	10	0
	$5 > u$	0	0	0	0	0
Hirlesti	$90 > u \geq 80$	51	60	6	2	2
	$80 > u \geq 70$	202	17	23	3	1
	$70 > u \geq 40$	45	15	38	6	0
	$40 > u \geq 5$	5	91	50	25	0
	$5 > u$	0	0	0	0	0
Preajba	$90 > u \geq 80$	29	11	5	4	0
	$80 > u \geq 70$	12	35	6	0	0
	$70 > u \geq 40$	4	40	56	8	0
	$40 > u \geq 5$	0	4	18	5	0
	$5 > u$	0	0	0	0	0
Rosiori	$90 > u \geq 80$	23	4	3	1	1
	$80 > u \geq 70$	2	0	3	1	1
	$70 > u \geq 40$	1	4	22	6	0
	$40 > u \geq 5$	0	18	65	13	0
	$5 > u$	0	0	0	0	0
Traianu	$90 > u \geq 80$	20	10	10	3	1
	$80 > u \geq 70$	8	14	16	4	1
	$70 > u \geq 40$	3	24	14	3	1
	$40 > u \geq 5$	0	84	75	14	0
	$5 > u$	0	0	0	0	0
Videle	$90 > u \geq 80$	34	31	5	2	0
	$80 > u \geq 70$	10	78	6	1	0
	$70 > u \geq 40$	3	13	17	2	1
	$40 > u \geq 5$	1	12	22	11	0
	$5 > u$	0	0	0	0	0

Distributie Oltenia SA
Directia Exploatare&Mentenanata
Dpt. Exploatare 110 kV
CE 110 kV Pitesti

Date extrase din analizoarele de energie electrica pe parcursul anului 2016

Statia	Tabel 5					
	Tensiunea reziduala u %	Durata t [ms]				
		$10 \leq t \leq 200$	$200 < t \leq 500$	$500 < t \leq 1000$	$1000 < t \leq 5000$	$5000 < t \leq 60000$
Arges Sud (20kV)	$90 > u \geq 80$	31	0	0	0	1
	$80 > u \geq 70$	3	0	0	0	0
	$70 > u \geq 40$	2	1	1	0	0
	$40 > u \geq 5$	0	0	9	4	2
	$5 > u$	0	0	0	0	0
Campulung (20kV)	$90 > u \geq 80$	28	2	1	0	0
	$80 > u \geq 70$	6	5	1	0	0
	$70 > u \geq 40$	0	7	1	2	1
	$40 > u \geq 5$	0	16	3	5	3
	$5 > u$	0	0	0	0	0
Electroarges (20kV)	$90 > u \geq 80$	48	16	1	0	0
	$80 > u \geq 70$	2	12	2	1	1
	$70 > u \geq 40$	2	10	5	1	0
	$40 > u \geq 5$	0	17	71	5	1
	$5 > u$	0	0	0	0	0
FMPE (20kV)	$90 > u \geq 80$	40	1	0	0	0
	$80 > u \geq 70$	20	7	0	0	0
	$70 > u \geq 40$	4	17	5	1	0
	$40 > u \geq 5$	4	29	33	7	0
	$5 > u$	0	0	0	0	0
Mozaceni (20kV)	$90 > u \geq 80$	170	151	15	2	2
	$80 > u \geq 70$	34	136	38	1	0
	$70 > u \geq 40$	2	51	82	9	0
	$40 > u \geq 5$	0	18	161	13	1
	$5 > u$	0	0	0	0	0
Patroaia (20kV)	$90 > u \geq 80$	7	4	0	1	1
	$80 > u \geq 70$	5	4	7	0	0
	$70 > u \geq 40$	0	1	5	5	1
	$40 > u \geq 5$	0	6	24	3	2
	$5 > u$	0	0	0	0	0
Pitesti Nord (20kV)	$90 > u \geq 80$	16	5	0	0	0
	$80 > u \geq 70$	31	41	0	0	0
	$70 > u \geq 40$	15	68	2	0	0
	$40 > u \geq 5$	3	0	0	0	0
	$5 > u$	0	0	0	0	0
Pitesti Vest (20kV)	$90 > u \geq 80$	19	0	0	0	0
	$80 > u \geq 70$	9	2	0	0	0
	$70 > u \geq 40$	22	0	0	0	0
	$40 > u \geq 5$	38	3	0	0	0
	$5 > u$	0	0	0	0	0
Rucar (20kV)	$90 > u \geq 80$	32	2	0	0	0
	$80 > u \geq 70$	4	5	1	0	1
	$70 > u \geq 40$	1	0	0	1	0
	$40 > u \geq 5$	0	0	3	5	0
	$5 > u$	0	0	0	0	0
Topoloveni (20kV)	$90 > u \geq 80$	17	10	0	0	0
	$80 > u \geq 70$	22	21	6	0	1
	$70 > u \geq 40$	2	11	24	4	2
	$40 > u \geq 5$	0	2	30	10	1
	$5 > u$	0	0	0	0	0
Valea Danului (20kV)	$90 > u \geq 80$	68	2	2	0	0
	$80 > u \geq 70$	22	3	1	0	0
	$70 > u \geq 40$	19	12	3	2	0
	$40 > u \geq 5$	3	12	8	4	1
	$5 > u$	0	0	0	0	0

Distributie Oltenia SA
Directia Exploatare&Mentenanata
Dpt. Exploatare 110 kV
CE 110 kV Craiova

Date extrase din analizoarele de energie electrica pe parcursul anului 2016

Statia	Tabel 5					
	Tensiunea reziduala u %	Durata t [ms]				
		$10 \leq t \leq 200$	$200 < t \leq 500$	$500 < t \leq 1000$	$1000 < t \leq 5000$	$5000 < t \leq 60000$
Cv-Est (6kV)	$90 > u \geq 80$	12	0	0	0	0
	$80 > u \geq 70$	1	1	0	0	0
	$70 > u \geq 40$	1	2	0	0	0
	$40 > u \geq 5$	0	1	0	1	0
	$5 > u$	0	0	0	0	0
Cv-Sud (6kV)	$90 > u \geq 80$	10	1	0	0	0
	$80 > u \geq 70$	9	1	0	0	0
	$70 > u \geq 40$	2	1	0	0	0
	$40 > u \geq 5$	2	1	0	1	0
	$5 > u$	0	0	0	0	0
Craiovia (6kV)	$90 > u \geq 80$	8	0	1	0	0
	$80 > u \geq 70$	7	0	0	0	0
	$70 > u \geq 40$	1	1	0	0	0
	$40 > u \geq 5$	0	0	0	1	0
	$5 > u$	0	0	0	0	0
Almaj (20kV)	$90 > u \geq 80$	40	30	1	2	0
	$80 > u \geq 70$	12	106	19	2	1
	$70 > u \geq 40$	2	97	27	0	0
	$40 > u \geq 5$	0	52	22	5	1
	$5 > u$	0	0	0	0	0
Bailesti (20kV)	$90 > u \geq 80$	76	56	6	1	3
	$80 > u \geq 70$	7	71	1	0	1
	$70 > u \geq 40$	5	74	9	2	1
	$40 > u \geq 5$	1	155	41	12	0
	$5 > u$	0	0	0	0	0
Basarabi (20kV)	$90 > u \geq 80$	20	5	2	0	0
	$80 > u \geq 70$	7	15	3	2	0
	$70 > u \geq 40$	13	15	20	3	0
	$40 > u \geq 5$	0	5	70	21	2
	$5 > u$	0	0	0	0	0
Craiova Centru (20kV)	$90 > u \geq 80$	3	1	0	1	0
	$80 > u \geq 70$	2	0	0	0	0
	$70 > u \geq 40$	3	1	0	0	0
	$40 > u \geq 5$	1	6	1	1	0
	$5 > u$	0	0	0	0	0
Moflesti (20kV)	$90 > u \geq 80$	288	20	3	2	0
	$80 > u \geq 70$	148	70	3	1	1
	$70 > u \geq 40$	15	75	11	3	0
	$40 > u \geq 5$	2	23	6	2	2
	$5 > u$	0	0	0	0	0
Prefabricate (20kV)	$90 > u \geq 80$	20	1	2	0	0
	$80 > u \geq 70$	5	1	0	0	0
	$70 > u \geq 40$	40	9	2	0	0
	$40 > u \geq 5$	59	21	13	4	2
	$5 > u$	0	0	0	0	0
Galicea (20kV)	$90 > u \geq 80$	15	5	0	0	0
	$80 > u \geq 70$	4	1	0	0	0
	$70 > u \geq 40$	7	6	0	2	0
	$40 > u \geq 5$	6	2	0	0	0
	$5 > u$	0	0	0	0	0

Distributie Oltenia SA
 Directia Exploatare&Mentenanata
 Dpt. Exploatare 110 kV
 CE 110 kV Targu-Jiu

Date extrase din analizoarele de energie electrica pe parcursul anului 2016

Statia	Tabel 5					
	Tensiunea reziduala u %	Durata t [ms]				
		$10 \leq t \leq 200$	$200 < t \leq 500$	$500 < t \leq 1000$	$1000 < t \leq 5000$	$5000 < t \leq 60000$
Ticleni (20kV)	$90 > u \geq 80$	73	1	0	0	0
	$80 > u \geq 70$	27	0	1	0	0
	$70 > u \geq 40$	17	4	3	2	0
	$40 > u \geq 5$	1	2	0	0	0
	$5 > u$	0	0	0	0	0
Ticleni (6kV)	$90 > u \geq 80$	56	1	1	0	0
	$80 > u \geq 70$	25	2	1	1	0
	$70 > u \geq 40$	13	4	4	1	2
	$40 > u \geq 5$	1	0	0	1	0
	$5 > u$	0	0	0	0	0
Turburea (6kV)	$90 > u \geq 80$	24	7	2	0	0
	$80 > u \geq 70$	1	0	1	1	0
	$70 > u \geq 40$	1	0	0	1	0
	$40 > u \geq 5$	0	0	0	0	0
	$5 > u$	0	0	0	0	0
Cauciuc (6kV)	$90 > u \geq 80$	22	2	1	1	0
	$80 > u \geq 70$	3	0	0	1	0
	$70 > u \geq 40$	0	1	0	0	0
	$40 > u \geq 5$	0	0	0	0	0
	$5 > u$	0	0	0	0	0
Barbatesti (6kV)	$90 > u \geq 80$	17	1	2	0	0
	$80 > u \geq 70$	7	4	0	0	0
	$70 > u \geq 40$	3	2	1	1	1
	$40 > u \geq 5$	0	0	0	0	0
	$5 > u$	0	0	0	0	0
Barsesti 2 (20kV)	$90 > u \geq 80$	10	8	11	2	1
	$80 > u \geq 70$	1	9	8	1	2
	$70 > u \geq 40$	0	2	9	1	1
	$40 > u \geq 5$	0	2	18	20	1
	$5 > u$	0	0	0	0	0
Barbatesti (20kV)	$90 > u \geq 80$	3	0	0	0	0
	$80 > u \geq 70$	1	0	0	0	0
	$70 > u \geq 40$	0	0	0	1	0
	$40 > u \geq 5$	0	0	0	0	0
	$5 > u$	0	0	0	0	0
Carbunesti (20kV)	$90 > u \geq 80$	4	0	0	0	0
	$80 > u \geq 70$	1	1	0	0	0
	$70 > u \geq 40$	0	2	0	1	0
	$40 > u \geq 5$	0	4	1	2	1
	$5 > u$	0	0	0	0	0
Godinesti (20kV)	$90 > u \geq 80$	11	2	5	5	0
	$80 > u \geq 70$	2	1	0	2	0
	$70 > u \geq 40$	4	2	1	6	1
	$40 > u \geq 5$	0	1	0	21	0
	$5 > u$	0	0	0	0	0
IUM (20kV)	$90 > u \geq 80$	24	4	2	0	0
	$80 > u \geq 70$	4	6	4	1	1
	$70 > u \geq 40$	1	8	5	0	0
	$40 > u \geq 5$	0	2	0	0	1
	$5 > u$	0	0	0	0	0
Jilt (20kV)	$90 > u \geq 80$	23	1	0	0	1
	$80 > u \geq 70$	10	4	0	0	2
	$70 > u \geq 40$	3	10	7	0	0
	$40 > u \geq 5$	0	2	7	1	0
	$5 > u$	0	0	0	0	0

Distributie Oltenia SA
 Directia Exploatare&Mentenanata
 Dpt. Exploatare 110 kV
 CE 110 kV Slatina

Date extrase din analizoarele de energie electrica pe parcursul anului 2016

Statia	Tabel 5					
Bals (20kV)	Tensiunea reziduala u %	Durata t [ms]				
		$10 \leq t \leq 200$	$200 < t \leq 500$	$500 < t \leq 1000$	$1000 < t \leq 5000$	$5000 < t \leq 60000$
	$90 > u \geq 80$	8	4	15	1	1
	$80 > u \geq 70$	2	1	10	3	2
	$70 > u \geq 40$	0	2	12	1	3
	$40 > u \geq 5$	0	0	39	4	1
	$5 > u$	0	0	0	0	0
Corabia (20kV)	$90 > u \geq 80$	37	18	2	5	3
	$80 > u \geq 70$	10	15	9	1	0
	$70 > u \geq 40$	0	6	14	3	4
	$40 > u \geq 5$	0	6	34	7	1
	$5 > u$	0	0	0	0	0
Icoana (20kV)	$90 > u \geq 80$	1	0	1	0	0
	$80 > u \geq 70$	2	0	0	0	0
	$70 > u \geq 40$	2	0	0	0	0
	$40 > u \geq 5$	0	0	0	0	0
	$5 > u$	0	0	0	0	0
Mamura (20kV)	$90 > u \geq 80$	13	1	0	1	0
	$80 > u \geq 70$	1	1	2	0	0
	$70 > u \geq 40$	2	4	0	0	0
	$40 > u \geq 5$	0	0	3	5	2
	$5 > u$	0	0	0	0	0
Milcov (20kV)	$90 > u \geq 80$	8	4	1	0	0
	$80 > u \geq 70$	3	0	0	0	0
	$70 > u \geq 40$	6	2	0	0	0
	$40 > u \geq 5$	1	15	0	0	0
	$5 > u$	0	0	0	0	0
Scornicesti (20kV)	$90 > u \geq 80$	130	26	9	3	2
	$80 > u \geq 70$	40	20	17	3	1
	$70 > u \geq 40$	4	29	48	10	1
	$40 > u \geq 5$	5	37	161	39	3
	$5 > u$	0	0	0	0	0
Slatina Nord (20kV)	$90 > u \geq 80$	48	2	4	3	0
	$80 > u \geq 70$	6	13	0	0	0
	$70 > u \geq 40$	4	12	13	3	0
	$40 > u \geq 5$	1	70	31	10	0
	$5 > u$	0	0	0	0	0

Distributie Oltenia SA
Directia Exploatare&Mentenanata
Dpt. Exploatare 110 kV
CE 110 kV Severin

Date extrase din analizoarele de energie electrica pe parcursul anului 2016

Statia	Tabel 5					
Anvelope (6kV)	Tensiunea reziduala u %	Durata t [ms]				
		$10 \leq t \leq 200$	$200 < t \leq 500$	$500 < t \leq 1000$	$1000 < t \leq 5000$	$5000 < t \leq 60000$
	$90 > u \geq 80$	16	0	0	0	0
	$80 > u \geq 70$	1	0	0	0	0
	$70 > u \geq 40$	1	0	0	0	0
	$40 > u \geq 5$	0	0	0	0	0
	$5 > u$	0	0	0	0	0
Banovita (20kV)	$90 > u \geq 80$	65	42	1	0	1
	$80 > u \geq 70$	16	32	3	1	0
	$70 > u \geq 40$	8	62	14	2	1
	$40 > u \geq 5$	0	108	47	6	1
	$5 > u$	0	0	0	0	0

Distributie Oltenia SA
Directia Exploatare&Mentenanata
Dpt. Exploatare 110 kV
CE 110 kV Valcea

Date extrase din analizoarele de energie electrica pe parcursul anului 2016

Statia	Tabel 5					
	Tensiunea reziduala u %	Durata t [ms]				
		$10 \leq t \leq 200$	$200 < t \leq 500$	$500 < t \leq 1000$	$1000 < t \leq 5000$	$5000 < t \leq 60000$
Alunu (20kV)	$90 > u \geq 80$	18	0	1	0	0
	$80 > u \geq 70$	0	0	0	1	0
	$70 > u \geq 40$	3	1	0	0	0
	$40 > u \geq 5$	3	2	0	1	0
	$5 > u$	0	0	0	0	0
Berbesti (20kV)	$90 > u \geq 80$	17	3	2	1	0
	$80 > u \geq 70$	5	7	0	0	0
	$70 > u \geq 40$	2	12	9	0	0
	$40 > u \geq 5$	0	2	5	2	0
	$5 > u$	0	0	0	0	0
Cazanesti (20kV)	$90 > u \geq 80$	17	14	2	0	0
	$80 > u \geq 70$	2	11	1	0	0
	$70 > u \geq 40$	1	10	1	0	2
	$40 > u \geq 5$	0	16	13	2	0
	$5 > u$	0	0	0	0	0
Jiblea (20kV)	$90 > u \geq 80$	12	1	2	1	3
	$80 > u \geq 70$	0	0	1	0	1
	$70 > u \geq 40$	0	4	5	2	3
	$40 > u \geq 5$	0	7	12	3	1
	$5 > u$	0	0	0	0	0
Ladesti (20kV)	$90 > u \geq 80$	7	0	0	0	0
	$80 > u \geq 70$	3	1	0	0	0
	$70 > u \geq 40$	0	1	0	0	0
	$40 > u \geq 5$	0	3	3	2	0
	$5 > u$	0	0	0	0	0
Traian (20kV)	$90 > u \geq 80$	8	9	1	0	0
	$80 > u \geq 70$	0	16	2	0	0
	$70 > u \geq 40$	2	3	3	1	0
	$40 > u \geq 5$	0	1	2	1	0
	$5 > u$	0	0	0	0	0
Valcea Nord (20kV)	$90 > u \geq 80$	5	0	0	0	0
	$80 > u \geq 70$	2	0	0	0	0
	$70 > u \geq 40$	0	3	0	0	0
	$40 > u \geq 5$	7	25	4	0	0
	$5 > u$	0	0	0	0	0
Valcea Sud (20kV)	$90 > u \geq 80$	35	10	8	21	3
	$80 > u \geq 70$	3	6	0	0	1
	$70 > u \geq 40$	1	4	1	0	0
	$40 > u \geq 5$	0	6	2	3	0
	$5 > u$	0	0	0	0	0
Valcea Sud (110kV)	$90 > u \geq 80$	2	0	0	0	0
	$80 > u \geq 70$	0	0	0	0	0
	$70 > u \geq 40$	0	0	0	0	0
	$40 > u \geq 5$	0	0	0	0	0
	$5 > u$	0	0	0	0	0