

Nume OD: SC CEZ DISTRIBUTIE SA
ANEXA 1- 01.01.2009 - 31.12.2009

Indicator	UM	Valoare
ENS	MWh	32.540
AD	MWh	2,496,830.78
AIT	min/an	6.85

Nume OD: SC CEZ DISTRIBUTIE SA
ANEXA 1-PERIOADA 01.01.2009 - 31.12.2009

Tens client	Originea intreruperii	Indicator	Loc consum	FTT	IT	MT	JT	TOTAL
	Tip intrerupere							
	▼							
IT	a)Intreruperi planificate	SAIFI	urban	-	-	-	-	-
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	urban	-	-	-	-	-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban	-	-	-	-	-
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban	-	-	-	-	-
	TOTAL b+c+d	SAIFI	urban	-	-	-	-	-
MT	a)Intreruperi planificate	SAIFI	urban	-	-	0.18	-	0.18
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	urban	-	-	0.01	-	0.01
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban	-	-	0.14	-	0.14
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban	-	0.05	3.54	-	3.59
	TOTAL b+c+d	SAIFI	urban	-	0.05	3.69	-	3.74
JT	a)Intreruperi planificate	SAIFI	urban	-	-	0.25	0.40	0.65
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	urban	-	-	0.02	-	0.02
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban	-	-	0.07	0.01	0.08
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban	-	0.03	4.36	0.50	4.89
	TOTAL b+c+d	SAIFI	urban	-	0.03	4.45	0.51	4.99
IT	a)Intreruperi planificate	SAIDI	urban	-	-	-	-	-
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	urban	-	-	-	-	-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban	-	-	-	-	-
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban	-	-	-	-	-
	TOTAL b+c+d	SAIDI	urban	-	-	-	-	-
MT	a)Intreruperi planificate	SAIDI	urban	-	-	29.28	-	29.28
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	urban	-	-	2.14	-	2.14
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban	-	-	10.99	-	10.99
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban	-	0.78	292.43	-	293.21
	TOTAL b+c+d	SAIDI	urban	-	0.78	305.56	-	306.34
JT	a)Intreruperi planificate	SAIDI	urban	-	-	59.70	93.22	152.92
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	urban	-	-	3.56	-	3.56
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban	-	-	4.49	1.44	5.93
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban	-	0.62	356.19	83.11	439.92
	TOTAL b+c+d	SAIDI	urban	-	0.62	364.24	84.55	449.41
IT	a)Intreruperi planificate	SAIFI	rural	-	-	-	-	-
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	rural	-	-	-	-	-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural	-	-	-	-	-
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural	-	0.29	-	-	0.29
	TOTAL b+c+d	SAIFI	rural	-	0.29	-	-	0.29
MT	a)Intreruperi planificate	SAIFI	rural	-	-	0.82	-	0.82
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	rural	-	-	-	-	-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural	-	-	0.54	-	0.54
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural	-	0.03	8.33	-	8.36
	TOTAL b+c+d	SAIFI	rural	-	0.03	8.87	-	8.90
JT	a)Intreruperi planificate	SAIFI	rural	-	-	0.99	0.65	1.64
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	rural	-	-	-	-	-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural	-	-	0.36	0.01	0.37
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural	-	0.04	10.15	0.75	10.93
	TOTAL b+c+d	SAIFI	rural	-	0.04	10.51	0.75	11.30
IT	a)Intreruperi planificate	SAIDI	rural	-	-	-	-	-
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	rural	-	-	-	-	-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural	-	-	-	-	-
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural	-	6.71	-	-	6.71
	TOTAL b+c+d	SAIDI	rural	-	6.71	-	-	6.71
MT	a)Intreruperi planificate	SAIDI	rural	-	-	158.76	-	158.76
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	rural	-	-	-	-	-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural	-	-	65.51	-	65.51
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural	-	0.60	878.89	-	879.49
	TOTAL b+c+d	SAIDI	rural	-	0.60	944.40	-	945.00
JT	a)Intreruperi planificate	SAIDI	rural	-	-	251.63	172.29	423.92
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	rural	-	-	-	-	-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural	-	-	50.07	1.00	51.07
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural	-	0.95	1,133.14	197.80	1,331.89
	TOTAL b+c+d	SAIDI	rural	-	0.95	1,183.21	198.80	1,382.96
IT		Nr utilizatori IT	urban		45			45
MT		Nr utilizatori MT	urban			1,097		1,097
JT		Nr utilizatori JT	urban				593,259	593,259
IT		Nr utilizatori IT	rural		38			38
MT		Nr utilizatori MT	rural			1,887		1,887
JT		Nr utilizatori JT	rural				789,641	789,641

* Pentru aceste calcule, in notiunea de utilizator se inglobeaza consumatorii, locurile de productie si alti operatori racordati in retea