

Nume OD: SC CEZ DISTRIBUTIE SA
ANEXA 1- 01.01.2011 - 31.12.2011

Indicator	UM	Valoare
ENS	MWh	63.380
AD	MWh	2,647,064.11
AIT	min/an	12.58

Nume OD: SC CEZ DISTRIBUTIE SA
ANEXA 1-PERIOADA 01.01.2011 - 31.12.2011

Tens client	Originea intreruperii	Indicator	Loc consum	FT	IT	MT	JT	TOTAL
	Tip intrerupere ▼							
IT	a)Intreruperi planificate	SAIFI	urban	-	-			-
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	urban	-	-			-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban	-	-			-
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban	-	0.30			0.300
	TOTAL b+c+d	SAIFI	urban	-	0.30			0.300
MT	a)Intreruperi planificate	SAIFI	urban	-	-	0.340		0.340
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	urban	-	-	0.140		0.140
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban	-	-	0.170		0.170
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban	-	0.140	3.930		4.070
	TOTAL b+c+d	SAIFI	urban	-	0.140	4.240		4.380
JT	a)Intreruperi planificate	SAIFI	urban	-	-	0.315	0.198	0.513
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	urban	-	-	0.146	-	0.146
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban	-	-	0.063	0.002	0.065
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban	-	0.119	3.390	0.276	3.785
	TOTAL b+c+d	SAIFI	urban	-	0.119	3.599	0.278	3.996
IT	a)Intreruperi planificate	SAIDI	urban	-	-			-
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	urban	-	-			-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban	-	-			-
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban	-	26.66			26.66
	TOTAL b+c+d	SAIDI	urban	-	26.66			26.66
MT	a)Intreruperi planificate	SAIDI	urban	-	-	91.01		91.01
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	urban	-	-	29.92		29.92
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban	-	-	28.94		28.94
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban	-	1.24	322.72		323.96
	TOTAL b+c+d	SAIDI	urban	-	1.24	381.58		382.82
JT	a)Intreruperi planificate	SAIDI	urban	-	-	77.55	38.25	115.80
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	urban	-	-	30.07	-	30.07
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban	-	-	17.70	0.53	18.23
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban	-	1.22	280.09	45.46	326.77
	TOTAL b+c+d	SAIDI	urban	-	1.22	327.86	45.99	375.07
IT	a)Intreruperi planificate	SAIFI	rural	-	-	-	-	-
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	rural	-	-	-	-	-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural	-	-	-	-	-
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural	-	0.580			0.580
	TOTAL b+c+d	SAIFI	rural	-	0.580			0.580
MT	a)Intreruperi planificate	SAIFI	rural	-	-	0.760		0.760
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	rural	-	-	0.590		0.590
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural	-	-	0.290		0.290
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural	-	0.100	6.290		6.390
	TOTAL b+c+d	SAIFI	rural	-	0.100	7.170		7.270
JT	a)Intreruperi planificate	SAIFI	rural	-	-	1.181	0.641	1.822
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	rural	-	-	0.732	-	0.732
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural	-	-	0.237	0.005	0.242
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural	-	0.091	8.251	0.603	8.946
	TOTAL b+c+d	SAIFI	rural	-	0.091	9.220	0.608	9.920
IT	a)Intreruperi planificate	SAIDI	rural	-	-			-
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	rural	-	-			-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural	-	-			-
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural	-	24.08			24.08
	TOTAL b+c+d	SAIDI	rural	-	24.08			24.08
MT	a)Intreruperi planificate	SAIDI	rural	-	-	199.00		199.00
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	rural	-	-	182.73		182.73
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural	-	-	35.45		35.45
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural	-	1.93	812.57		814.50
	TOTAL b+c+d	SAIDI	rural	-	1.93	1,030.75		1,032.68
JT	a)Intreruperi planificate	SAIDI	rural	-	-	354.08	153.62	507.70
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	rural	-	-	235.87	-	235.87
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural	-	-	26.48	1.29	27.77
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural	-	1.37	1,165.80	151.83	1,319.00
	TOTAL b+c+d	SAIDI	rural	-	1.37	1,428.15	153.12	1,582.64
IT		Nr utilizatori IT	urban		44			44
MT		Nr utilizatori MT	urban			1,103		1,103
JT		Nr utilizatori JT	urban				594,600	594,600
IT		Nr utilizatori IT	rural		38			38
MT		Nr utilizatori MT	rural			2,010		2,010
JT		Nr utilizatori JT	rural				794,573	794,573

* Pentru aceste calcule, in notiunea de utilizator se inglobeaza consumatorii, locurile de productie si alti operatori racordati in retea