

Nume OD: SC CEZ DISTRIBUTIE SA
ANEXA 1- 01.01.2012 - 31.12.2012

Indicator	UM	Valoare
ENS	MWh	148.48
AD	MWh	2,182,219
AIT	min/an	35.76

Nume OD: SC CEZ DISTRIBUTIE SA
ANEXA 1-PERIOADA 01.01.2012 - 31.12.2012

Tens client	Originea intreruperii	Indicator	Loc consum	FT	IT	MT	JT	TOTAL
	Tip intrerupere ▼							
IT	a)Intreruperi planificate	SAIFI	urban	-	-			-
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	urban	-	-			-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban	-	-			-
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban	-	0.240			0.240
	TOTAL b+c+d	SAIFI	urban	-	0.24			0.240
MT	a)Intreruperi planificate	SAIFI	urban	-	-	2.420		2.420
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	urban	-	-	0.190		0.190
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban	-	0.020	0.170		0.190
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban	-	0.110	4.050		4.160
	TOTAL b+c+d	SAIFI	urban	-	0.130	4.410		4.540
JT	a)Intreruperi planificate	SAIFI	urban	-	-	0.342	0.124	0.466
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	urban	-	-	0.142	0.01	0.148
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban	-	0.017	0.069	0.001	0.086
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban	-	0.197	3.414	0.249	3.860
	TOTAL b+c+d	SAIFI	urban	-	0.214	3.624	0.256	4.094
IT	a)Intreruperi planificate	SAIDI	urban	-	-			-
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	urban	-	-			-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban	-	-			-
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban	-	8.38			8.38
	TOTAL b+c+d	SAIDI	urban	-	8.38			8.38
MT	a)Intreruperi planificate	SAIDI	urban	-	-	514.45		514.45
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	urban	-	-	58.62		58.62
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban	-	0.11	9.61		9.72
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban	-	9.38	411.69		421.07
	TOTAL b+c+d	SAIDI	urban	-	9.49	479.92		489.41
JT	a)Intreruperi planificate	SAIDI	urban	-	-	72.17	24.81	96.98
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	urban	-	-	42.46	2.03	44.49
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban	-	0.10	4.25	0.15	4.50
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban	-	12.88	241.38	43.95	298.21
	TOTAL b+c+d	SAIDI	urban	-	12.98	288.09	46.13	347.20
IT	a)Intreruperi planificate	SAIFI	rural	-	-	-	-	-
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	rural	-	-	-	-	-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural	-	-	-	-	-
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural	-	0.020			0.020
	TOTAL b+c+d	SAIFI	rural	-	0.020			0.020
MT	a)Intreruperi planificate	SAIFI	rural	-	-	2.170		2.170
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	rural	-	-	0.540		0.540
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural	-	-	0.360		0.360
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural	-	0.140	7.270		7.410
	TOTAL b+c+d	SAIFI	rural	-	0.140	8.170		8.310
JT	a)Intreruperi planificate	SAIFI	rural	-	-	1.406	0.392	1.798
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	rural	-	0.01	0.681	0.03	0.717
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural	-	0.01	0.286	0.002	0.297
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural	-	0.183	7.823	0.566	8.572
	TOTAL b+c+d	SAIFI	rural	-	0.198	8.790	0.598	9.586
IT	a)Intreruperi planificate	SAIDI	rural	-	-			-
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	rural	-	-			-
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural	-	-			-
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural	-	5.77			5.77
	TOTAL b+c+d	SAIDI	rural	-	5.77			5.77
MT	a)Intreruperi planificate	SAIDI	rural	-	-	395.17		395.17
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	rural	-	1.06	432.73		433.79
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural	-	0.06	25.37		25.43
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural	-	10.48	1,001.91		1,012.39
	TOTAL b+c+d	SAIDI	rural	-	11.60	1,460.01		1,471.61
JT	a)Intreruperi planificate	SAIDI	rural	-	-	339.10	94.29	433.39
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	rural	-	1.62	551.00	16.23	568.85
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural	-	0.20	28.76	0.54	29.50
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural	-	12.98	1,079.04	147.13	1,239.15
	TOTAL b+c+d	SAIDI	rural	-	14.80	1,658.80	163.90	1,837.50
IT		Nr utilizatori IT	urban		37			37
MT		Nr utilizatori MT	urban			1,132		1,132
JT		Nr utilizatori JT	urban				610,164	610,164
IT		Nr utilizatori IT	rural		44			44
MT		Nr utilizatori MT	rural			2,277		2,277
JT		Nr utilizatori JT	rural				783,934	783,934

* Pentru aceste calcule, in notiunea de utilizator se inglobeaza consumatorii, locurile de productie si alti operatori racordati in retea