

Nume OD: SC CEZ DISTRIBUTIE SA
ANEXA 1- 01.01.2013 - 31.12.2013

Indicator	UM	Valoare
ENS	MWh	66.95
AD	MWh	1,946,080
AIT	min/an	18.08

Tens client	Originea intreruperii	Indicator	Loc consum	FIT	IT	MT	JT	TOTAL
	Tip intrerupere							
	▼							
IT	a) Intreruperi planificate	SAIFI	urban	-	-			-
	b) Intreruperi neplanificate cauzate de forta majora	SAIFI	urban	-	-			-
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban	-	-			-
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban	-	0.333			0.333
	TOTAL b+c+d	SAIFI	urban	-	0.333			0.333
MT	a) Intreruperi planificate	SAIFI	urban	-	-	2.631		2.631
	b) Intreruperi neplanificate cauzate de forta majora	SAIFI	urban	-	-	0.125		0.125
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban	-	0.049	0.178		0.227
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban	-	0.132	3.659		3.791
	TOTAL b+c+d	SAIFI	urban	-	0.181	3.962		4.143
JT	a) Intreruperi planificate	SAIFI	urban	-	-	0.411	0.117	0.528
	b) Intreruperi neplanificate cauzate de forta majora	SAIFI	urban	-	-	0.056	0.0005	0.057
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban	-	0.018	0.064	0.00009	0.082
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban	-	0.144	2.594	0.186	2.924
	TOTAL b+c+d	SAIFI	urban	-	0.162	2.714	0.187	3.063
IT	a) Intreruperi planificate	SAIDI	urban	-	-			-
	b) Intreruperi neplanificate cauzate de forta majora	SAIDI	urban	-	-			-
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban	-	-			-
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban	-	13.15			13.15
	TOTAL b+c+d	SAIDI	urban	-	13.15			13.15
MT	a) Intreruperi planificate	SAIDI	urban	-	-	585.52		585.52
	b) Intreruperi neplanificate cauzate de forta majora	SAIDI	urban	-	-	17.48		17.48
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban	-	2.24	18.65		20.89
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban	-	2.04	298.26		300.30
	TOTAL b+c+d	SAIDI	urban	-	4.28	334.39		338.67
JT	a) Intreruperi planificate	SAIDI	urban	-	-	88.23	26.02	114.25
	b) Intreruperi neplanificate cauzate de forta majora	SAIDI	urban	-	-	6.61	0.19	6.80
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban	-	0.51	5.22	0.02	5.75
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban	-	1.98	170.23	29.80	202.01
	TOTAL b+c+d	SAIDI	urban	-	2.49	182.06	30.01	214.56
IT	a) Intreruperi planificate	SAIFI	rural	-	-			-
	b) Intreruperi neplanificate cauzate de forta majora	SAIFI	rural	-	-			-
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural	-	-			-
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural	-	0.227			0.227
	TOTAL b+c+d	SAIFI	rural	-	0.227			0.227
MT	a) Intreruperi planificate	SAIFI	rural	-	-	4.328		4.328
	b) Intreruperi neplanificate cauzate de forta majora	SAIFI	rural	-	-	1.753		1.753
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural	-	0.035	0.389		0.424
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural	-	0.202	10.916		11.118
	TOTAL b+c+d	SAIFI	rural	-	0.237	13.058		13.295
JT	a) Intreruperi planificate	SAIFI	rural	-	-	2.088	0.273	2.361
	b) Intreruperi neplanificate cauzate de forta majora	SAIFI	rural	-	-	0.304	0.0009	0.305
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural	-	0.032	0.325	0.001	0.358
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural	-	0.228	7.034	0.389	7.651
	TOTAL b+c+d	SAIFI	rural	-	0.260	7.663	0.391	8.313
IT	a) Intreruperi planificate	SAIDI	rural	-	-			-
	b) Intreruperi neplanificate cauzate de forta majora	SAIDI	rural	-	-			-
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural	-	-			-
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural	-	4.94			4.94
	TOTAL b+c+d	SAIDI	rural	-	4.94			4.94
MT	a) Intreruperi planificate	SAIDI	rural	-	-	1266.71		1,266.71
	b) Intreruperi neplanificate cauzate de forta majora	SAIDI	rural	-	-	567.53		567.53
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural	-	0.96	46.51		47.47
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural	-	3.36	1101.12		1,104.48
	TOTAL b+c+d	SAIDI	rural	-	4.32	1,715.16		1,719.48
JT	a) Intreruperi planificate	SAIDI	rural	-	-	595.01	69.74	664.75
	b) Intreruperi neplanificate cauzate de forta majora	SAIDI	rural	-	-	57.14	0.87	58.01
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural	-	0.95	31.70	0.27	32.92
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural	-	3.98	836.04	95.39	935.41
	TOTAL b+c+d	SAIDI	rural	-	4.93	924.88	96.53	1,026.34
IT	Nr utilizatori IT		urban		39			39
MT	Nr utilizatori MT		urban			1,167		1,167
JT	Nr utilizatori JT		urban				628,909	628,909
IT	Nr utilizatori IT		rural		44			44
MT	Nr utilizatori MT		rural			2,154		2,154
JT	Nr utilizatori JT		rural				772,431	772,431