

Nume OD: CEZ DISTRIBUTIE SA
ANEXA 1- 01.01.2015 - 31.12.2015

Indicator	UM	Valoare
ENS	MWh	140.29
AD	MWh	1,738,686
AIT	min/an	42.41

Nume OD: CEZ DISTRIBUTIE SA
ANEXA 1-PERIOADA 01.01.2015 - 31.12.2015

Tens client	Originea intreruperii Tip intrerupere ▼	Indicator	Loc consum					
				FIT	IT	MT	JT	TOTAL
IT	a) Intreruperi planificate	SAIFI	urban		-			0.000
	b) Intreruperi neplanificate cauzate de forta majora	SAIFI	urban		-			0.000
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban		0.06			0.065
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban		0.097			0.097
	TOTAL b+c+d	SAIFI	urban	-	0.161			0.161
MT	a) Intreruperi planificate	SAIFI	urban		-	0.477		0.477
	b) Intreruperi neplanificate cauzate de forta majora	SAIFI	urban		-	0.654		0.654
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban		0.000	0.373		0.373
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban		0.068	4.124		4.191
	TOTAL b+c+d	SAIFI	urban	-	0.068	5.151		5.218
JT	a) Intreruperi planificate	SAIFI	urban		-	0.286	0.055	0.341
	b) Intreruperi neplanificate cauzate de forta majora	SAIFI	urban		-	0.296	0.0013	0.298
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIFI	urban		0.000	0.103	0.00067	0.104
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	urban		0.094	2.469	0.145	2.709
	TOTAL b+c+d	SAIFI	urban	-	0.094	2.868	0.147	3.110
IT	a) Intreruperi planificate	SAIDI	urban		-			0.00
	b) Intreruperi neplanificate cauzate de forta majora	SAIDI	urban		-			0.00
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban		2.26			2.26
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban		3.23			3.23
	TOTAL b+c+d	SAIDI	urban	-	5.48			5.48
MT	a) Intreruperi planificate	SAIDI	urban		-	104.71		104.71
	b) Intreruperi neplanificate cauzate de forta majora	SAIDI	urban		-	111.84		111.84
	c) Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban		0.00	28.73		28.73
	d) Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban		1.23	327.54		328.77

	TOTAL b+c+d	SAIDI	urban	-	1.23	468.12		469.35
JT	a)Intreruperi planificate	SAIDI	urban		-	58.11	8.94	67.05
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	urban		-	31.58	0.39	31.98
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	urban		0.00	7.65	0.07	7.71
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	urban		1.04	164.77	20.91	186.72
	TOTAL b+c+d	SAIDI	urban	-	1.04	204.00	21.37	226.41
IT	a)Intreruperi planificate	SAIFI	rural		-			0.00
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	rural		0.04			0.04
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural		0.06			0.06
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural		0.185			0.185
	TOTAL b+c+d	SAIFI	rural	-	0.278			0.278
MT	a)Intreruperi planificate	SAIFI	rural		-	1.271		1.271
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	rural		-	1.436		1.436
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural		0.004	0.949		0.953
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural		0.093	6.667		6.760
	TOTAL b+c+d	SAIFI	rural	-	0.097	9.053		9.150
JT	a)Intreruperi planificate	SAIFI	rural		-	1.220	0.100	1.320
	b)Intreruperi neplanificate cauzate de forta majora	SAIFI	rural		-	1.114	0.0045	1.118
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIFI	rural		0.022	0.335	0.000	0.357
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIFI	rural		0.125	5.312	0.253	5.690
	TOTAL b+c+d	SAIFI	rural	-	0.147	6.761	0.258	7.166
IT	a)Intreruperi planificate	SAIDI	rural		-			0.00
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	rural		0.44			0.44
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural		1.18			1.18
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural		2.93			2.93
	TOTAL b+c+d	SAIDI	rural	-	4.56			4.56
MT	a)Intreruperi planificate	SAIDI	rural		-	254.45		254.45
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	rural		-	196.13		196.13
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural		0.05	87.82		87.87

	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural		2.00	637.67		639.67
	TOTAL b+c+d	SAIDI	rural	-	2.05	921.63		923.68
JT	a)Intreruperi planificate	SAIDI	rural		-	325.16	22.90	348.06
	b)Intreruperi neplanificate cauzate de forta majora	SAIDI	rural		-	177.97	2.17	180.15
	c)Intreruperi neplanificate cauzate de utilizatori*	SAIDI	rural		0.33	32.70	0.07	33.11
	d)Intreruperi neplanificate exclusiv intreruperile de la punctele b si c	SAIDI	rural		2.43	497.51	54.75	554.69
	TOTAL b+c+d	SAIDI	rural	-	2.76	708.19	56.99	767.94
IT		Nr utilizatori	urban		31			31
MT		Nr utilizatori MT	urban			1,375		1,375
JT		Nr utilizatori JT	urban				636,971	636,971
IT		Nr utilizatori	rural		54			54
MT		Nr utilizatori MT	rural			2,425		2,425
JT		Nr utilizatori JT	rural				780,728	780,728

* Pentru aceste calcule, in notiunea de utilizator se inglobeaza consumatorii, locurile de productie si alti operatori racordati in retea