

Anexa 2 - Monitorizarea intreruperilor de lunga durata

Nr. crt.	Indicatori performanta		Valoarea realizata lunar											
			1	2	3	4	5	6	7	8	9	10	11	12
1	Nr.intreruperi planificate in mediul urban	JT	102	178	187	126	104	117	105	84	127	168	105	59
		MT	13	21	41	34	35	19	21	15	26	28	20	17
		IT	0	0	0	0	0	0	0	0	0	0	0	0
2	Nr.intreruperi planificate in mediul rural	JT	280	494	510	373	375	242	265	249	357	345	199	163
		MT	28	48	95	73	75	51	64	42	47	64	51	36
		IT	0	0	0	0	0	0	0	0	0	0	0	0
3	Nr.intreruperi planificate in mediul urban pt.care restabilirea alim.cu energie el. s-a realizat in timpul planificat anuntat	JT	88	147	172	120	96	106	96	78	108	148	97	49
		MT	11	21	40	32	34	17	18	15	21	25	17	15
		IT	0	0	0	0	0	0	0	0	0	0	0	0
4	Nr.intreruperi planificate in mediul rural pt.care restabilirea alim.cu energie el. s-a realizat in timpul planificat anuntat	JT	234	423	476	333	354	225	232	225	321	302	186	137
		MT	19	43	85	60	71	44	53	33	44	54	49	29
		IT	0	0	0	0	0	0	0	0	0	0	0	0
5	Durata medie a unei intreruperi planificate in mediul urban - min	JT	165.60	178.80	198.00	216.00	258.00	245.40	231.60	210.00	246.00	186.60	210.00	208.20
		MT	186.00	210.00	254.40	290.40	305.40	229.20	315.60	238.80	322.20	205.20	235.20	262.80
		IT	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6	Durata medie a unei intreruperi planificate in mediul rural - min	JT	223.80	214.20	250.20	233.40	245.40	230.40	246.00	256.80	213.00	202.80	249.60	224.40
		MT	292.80	278.40	304.80	309.60	304.20	267.00	269.40	274.80	249.00	232.80	279.60	233.40
		IT	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	Nr.intreruperi neplanificate in mediul urban	JT	3,153	2,830	3,364	3,382	3,312	3,339	3,928	3,214	3,207	3,473	3,315	4,241
		MT	135	57	98	103	107	187	282	126	113	131	70	177
		IT	0	1	0	0	0	3	6	0	0	0	1	0
8	Nr.intreruperi neplanificate in mediul rural	JT	6,304	5,005	8,094	8,643	7,242	8,140	10,131	7,856	7,345	6,887	6,027	9,305
		MT	271	102	212	180	193	288	538	224	197	203	120	378
		IT	1	0	1	4	2	6	3	0	2	0	0	2
9	Nr.intreruperi neplanificate cu durata mai mică de 12 ore, pentru mediul urban	JT	3,038	2,822	3,352	3,354	3,293	3,302	3,831	3,197	3,189	3,462	3,310	4,193
		MT	118	57	94	103	104	183	263	122	108	129	69	163
		IT	0	1	0	0	0	3	6	0	0	0	1	0
10	Nr.intreruperi neplanificate cu durata mai mică de 24 ore, pentru mediul rural	JT	6,077	5,001	8,090	8,591	7,235	8,112	10,040	7,840	7,329	6,877	6,023	9,268
		MT	254	102	211	180	193	286	526	223	195	202	119	368
		IT	1	0	1	4	2	6	3	0	2	0	0	2
11	Durata medie a unei intreruperi neplanificate in mediul urban	JT	212.40	159.60	168.00	175.20	169.20	179.40	208.80	178.80	170.40	162.00	156.60	185.40
		MT	331.20	130.20	176.40	128.40	152.40	148.20	217.80	151.80	188.40	115.20	146.40	270.60
		IT	0.00	70.20	0.00	0.00	0.00	14.40	27.00	0.00	0.00	0.00	6.00	0.00
12	Durata medie a unei intreruperi neplanificate in mediul rural	JT	310.20	231.00	246.00	271.80	249.00	277.20	324.00	274.80	267.00	239.40	217.20	278.40
		MT	436.20	164.40	213.00	211.80	200.40	229.80	293.40	205.20	211.80	148.80	149.40	342.60
		IT	1411.80	0.00	21.00	194.40	12.60	19.80	15.60	0.00	27.00	0.00	0.00	40.80