

Anexa 2 - Monitorizarea intreruperilor de lunga durata

Nr. crt.	Indicatori performanta		Valoarea realizata lunar											
			1	2	3	4	5	6	7	8	9	10	11	12
1	Nr.intreruperi planificate in mediul urban	JT	194	152	194	146	233	156	147	147	150	189	220	140
		MT	14	8	21	4	24	25	18	22	31	34	31	11
		IT	0	0	0	0	0	0	0	0	0	0	0	0
2	Nr.intreruperi planificate in mediul rural	JT	551	431	1122	576	568	374	374	374	417	554	446	245
		MT	35	40	80	49	56	55	60	52	68	80	83	41
		IT	0	0	0	0	0	0	0	0	0	0	0	0
3	Nr.intreruperi planificate in mediul urban pt.care restabilirea alim.cu energie el. s-a realizat in timpul planificat anuntat	JT	174	142	172	123	203	138	134	129	119	137	179	114
		MT	10	8	18	3	20	20	16	18	22	29	21	10
		IT	0	0	0	0	0	0	0	0	0	0	0	0
4	Nr.intreruperi planificate in mediul rural pt.care restabilirea alim.cu energie el. s-a realizat in timpul planificat anuntat	JT	456	372	949	479	467	289	304	321	308	431	341	184
		MT	24	36	65	44	46	47	53	41	52	61	62	36
		IT	0	0	0	0	0	0	0	0	0	0	0	0
5	Durata medie a unei intreruperi planificate in mediul urban - min	JT	154.20	159.00	170.40	179.40	203.40	186.60	246.00	205.20	211.80	202.20	194.40	202.80
		MT	249.60	171.60	199.20	228.60	303.00	279.60	270.00	226.80	271.80	222.60	313.20	307.20
		IT	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
6	Durata medie a unei intreruperi planificate in mediul rural - min	JT	219.00	215.40	272.40	243.00	255.60	245.40	217.20	217.80	232.80	193.20	214.80	249.60
		MT	267.00	186.00	277.20	280.80	265.80	240.00	238.20	235.20	298.20	246.60	275.40	292.20
		IT	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
7	Nr.intreruperi neplanificate in mediul urban	JT	3,196	3,406	2,956	2,899	2,782	2,732	3,053	2,950	2,365	3,176	3,017	3,740
		MT	114	85	121	115	92	119	158	107	51	114	53	58
		IT	1	0	0	0	2	2	2	0	0	0	0	1
8	Nr.intreruperi neplanificate in mediul rural	JT	6,498	5,773	5,950	6,884	6,284	5,933	6,594	6,151	4,324	5,749	4,879	7,128
		MT	297	220	227	257	184	275	335	249	132	179	88	175
		IT	0	0	0	2	2	2	2	0	0	0	0	0
9	Nr.intreruperi neplanificate cu durata mai mică de 12 ore, pentru mediul urban	JT	3,072	3,345	2,880	2,810	2,730	2,629	2,919	2,874	2,307	3,118	2,976	3,622
		MT	98	81	121	115	90	110	150	103	51	113	53	54
		IT	1	0	0	0	2	2	2	0	0	0	0	1
10	Nr.intreruperi neplanificate cu durata mai mică de 24 ore, pentru mediul rural	JT	6,136	5,592	5,880	6,757	6,247	5,850	6,492	6,109	4,296	5,712	4,863	6,964
		MT	273	210	224	257	184	273	333	249	132	178	88	166
		IT	0	0	0	2	2	2	2	0	0	0	0	0
11	Durata medie a unei intreruperi neplanificate in mediul urban	JT	214.20	184.20	189.00	198.60	176.40	211.20	216.00	195.00	190.80	177.60	169.80	188.40
		MT	330.00	189.60	107.40	130.20	123.00	188.40	174.60	150.00	125.40	114.60	120.00	216.60
		IT	58.20	0.00	0.00	0.00	6.60	33.00	54.00	0.00	0.00	0.00	0.00	19.80
12	Durata medie a unei intreruperi neplanificate in mediul rural	JT	405.00	339.00	297.60	312.00	280.20	315.00	340.80	304.20	274.80	282.00	240.60	317.40
		MT	579.60	352.20	176.40	204.60	162.60	262.80	245.40	153.00	164.40	150.00	142.80	419.40
		IT	0.00	0.00	0.00	33.60	38.40	9.00	45.00	0.00	0.00	0.00	0.00	0.00